

DL4500-EDH+ Application Note using Kepserver

Channel

- Set DF1 driver to use the ethernet encapsulation

Device

- Set Ethernet Encapsulation
- Properties
- IP address of Cobox Microprocessor
- Port # 10001
- Protocol TCP/IP

Note:

- Port# is the RAW tunneled sockets setup in IAP configuration.
- Kepserver does not work with Redirector Software. Need to use Device Com Manager.
- If tried Kepserver need to reboot before RSLINX will work!